

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
AIRLINE CAMPGROUND	NEWOWNER	2018-05-01	No	7.D.1	Individual water services are improperly located, designed, protected, or sized.	
				7.G	Plumbing is unacceptable.	
				7.E	Electrical distribution system is improperly installed or maintained in accordance with applicable state and local codes and rules.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
AIRLINE CAMPGROUND	REGULAR	2020-07-15	No	3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
AIRLINE CAMPGROUND	REGULAR	2021-10-01	No	3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	