

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
SEBAGO LAKE MARINA	REGULAR	2019-08-29	No	7.D.1	Individual water services are improperly located, designed, protected, or sized.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
SEBAGO LAKE MARINA	REGULAR	2023-09-07	No		No Violations	