

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
BAR HARBOR CAMPGROUND	REGULAR	2019-08-15	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
BAR HARBOR CAMPGROUND	REGULAR	2021-10-07	No		No Violations	