

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
MOLASSES POND HOUSE	REGULAR	2019-07-17	No	7.D.1	Individual water services are improperly located, designed, protected, or sized.	
				7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
MOLASSES POND HOUSE	REGULAR	2021-09-29	No	3.F	Service building not provided within 500 feet of all sites.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
MOLASSES POND HOUSE	REGULAR	2023-07-24	No	3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	