

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
MOUNT DESERT CAMPGROUND INC	REGULAR	2018-07-16	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
MOUNT DESERT CAMPGROUND INC	REGULAR	2020-08-13	No	6.B	Openings to the outer air are not effectively protected against the entrance of flies and other flying insects by the use of self-closing doors, closed windows and screening.	
				6.B.2	Screen doors are not self closing and/or windows, doors, skylights, transoms, and other openings to the outer air are not tight-fitting and free of breaks.	
MOUNT DESERT CAMPGROUND INC	REGULAR	2023-07-12	No	3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
				6.B.2	Screen doors are not self closing and/or windows, doors, skylights, transoms, and other openings to the outer air are not tight-fitting and free of breaks.	