

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
DUCK PUDDLE CAMPGROUND	REGULAR	2019-07-24	No		No Violations	
DUCK PUDDLE CAMPGROUND	REGULAR	2019-07-24	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
				3.F	Service building not provided within 500 feet of all sites.	
DUCK PUDDLE CAMPGROUND	REGULAR	2022-08-23	No	6-301.14	Hand wash signage not provided for employee hand sink or lavatory.	N
				4-203.12.(B)	Ambient air and water temperature measuring device is not accurate. (Scaled to Fahrenheit)	N
				6-202.15	Outer openings are not protected from the entry of insects or rodents.	N
				4-903.11.(A). (C)	Single service/ single use items improperly stored or kept in the original package or stored by using other means that afford protection from contamination until used.	N
				6-202.14	Toilet room not enclosed, with a self closing, tight fitting door.	N
DUCK PUDDLE CAMPGROUND	REGULAR	2022-08-23	No	3.F.5	The floors, walls and ceiling of the sanitary building are not clean and in good repair and/or the toilets, lavatories and showers are not cleaned and disinfected daily and/or maintained in good repair.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
				9.A.5	Privy doors are not self-closing.	
				5.A.2	There are not a sufficient number of containers.	