

| Establishment Name  | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation   | Severity |
|---------------------|------------|------------|-------|------------|--|----------|
| BENTLEYS CAMPGROUND | REGULAR    | 2019-08-27 | No    |            | No Violations  |          |
| BENTLEYS CAMPGROUND | REGULAR    | 2022-09-16 | No    | 3.C        | Materials used for sewer connections are not semi-rigid, corrosion-resistant, non-absorbent, durable and water tight and/or sewer connections for seasonal campers not made with rigid pipe. |          |
|                     |            |            |       | 7.D        | There are no water supply outlets and/or water supply outlets are not backflow protected.  |          |