

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
CINEMAGIC GRAND MOVIE THEATER	REGULAR	2019-06-10	No		No Violations	
MHC PREMIER CLARKS POND	NEWOWNER	2022-03-01	No	6-301.14	Hand wash signage not provided for employee hand sink or lavatory.	N
				5-202.11.(A)	Plumbing improperly installed/maintained. (Unacceptable system)	C
				5-202.13	Air gap required.	C
				5-402.12	Grease trap not easily accessible.	N
				6-303.11	Insufficient lighting provided.	N