

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
GARDINER HIGH SCHOOL	REGULAR	2019-02-11	No	5-202.12	Hand washing facility not properly equipped/installed with hot water of at least 100 F.	N
				4-204.112.(D)	Temperature measuring devices are not easily readable.	N
				4-301.12.(A)	A manual ware washing sink with at least three compartments not provided.	N
				5-205.15	Plumbing system not properly maintained in good repair.	C
GARDINER HIGH SCHOOL	REGULAR	2019-11-05	No	2-102.11.(C). (2).(3).(17)	Person In Charge could not respond correctly to questions regarding areas of knowledge dealing with employee health.	C
				4-301.12.(A)	A manual ware washing sink with at least three compartments not provided.	N
GARDINER HIGH SCHOOL	REGULAR	2022-01-27	No	5-202.12	Hand washing facility not properly equipped/installed with hot water of at least 100 F.	N
				4-301.12.(A)	A manual ware washing sink with at least three compartments not provided.	N
GARDINER HIGH SCHOOL	REGULAR	2022-11-04	No	4-301.12.(A)	A manual ware washing sink with at least three compartments not provided.	N
				6-501.11	The physical facilities are in disrepair.	N
GARDINER HIGH SCHOOL	REGULAR	2024-01-05	No	4-703.11	Manual and/or mechanical methods of sanitizing incomplete.	C
				4-301.12.(A)	A manual ware washing sink with at least three compartments not provided.	N
				5-103.11.(B)	Insufficient hot water supply.	C