

| Establishment Name   | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation  | Severity |
|----------------------|------------|------------|-------|------------|---|----------|
| ANCHORAGE INN (POOL) | REGULAR    | 2022-11-15 | No    | 6.G.1      | Valves not tagged with metal or rigid plastic tags.   | N        |
|                      |            |            |       | 6.D.4      | Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit. | C        |