

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
ARNDTS AROOSTOOK RIVER LODGE & CAMPGROUND (POOL)	REGULAR	2019-08-14	No	6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				3.G.2	Appropriate test kit, DPD or FAS-DPD not provided, test kit not capable of testing for free and combined chlorine, pH, total alkalinity, calcium hardness and when used, cyanuric acid, reagents are over one year old and/or prohibited OTO kits and/or test strips are being used.	C