

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation | Severity |
|-----------------------------|------------|------------|-------|------------|--|----------|
| ATLANTIC BIRCHES INC (POOL) | REGULAR | 2019-07-26 | No | 3.C | Public pool or spa water is not continuously disinfected by a sanitizer that imparts an easily measured residual. | C |
| | | | | 6.C.8 | The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser. | C |
| | | | | 6.C.1 | Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool. | C |
| ATLANTIC BIRCHES INC (POOL) | REGULAR | 2023-06-08 | No | 4.C.1.a | Gate latch not at correct height. | C |
| | | | | 6.C.8 | The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser. | C |