

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
ATLANTIC BIRCHES INC (POOL)	REGULAR	2019-07-26	No	3.C	Public pool or spa water is not continuously disinfected by a sanitizer that imparts an easily measured residual.	C
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C
				6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C
ATLANTIC BIRCHES INC (POOL)	REGULAR	2023-06-08	No	4.C.1.a	Gate latch not at correct height.	C
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C