

| Establishment Name               | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation   | Severity |
|----------------------------------|------------|------------|-------|------------|--|----------|
| BASS HARBOR<br>CAMPGROUND (POOL) | REGULAR    | 2019-07-18 | No    | 3.G.2      | Appropriate test kit, DPD or FAS-DPD not provided, test kit not capable of testing for free and combined chlorine, pH, total alkalinity, calcium hardness and when used, cyanuric acid, reagents are over one year old and/or prohibited OTO kits and/or test strips are being used.   | C        |
|                                  |            |            |       | 3.G.1      | Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available. | C        |
|                                  |            |            |       | 3.C.3      | pH not correct.  | C        |