

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
BEACH ACRES PARK (POOL)	REGULAR	2019-07-08	No		No Violations	
BEACH ACRES PARK (POOL)	NEWOWNER	2023-06-07	No	5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				3.A.4	Manufacturers instructions not available.	C
				3.G.2	Appropriate test kit, DPD or FAS-DPD not provided, test kit not capable of testing for free and combined chlorine, pH, total alkalinity, calcium hardness and when used, cyanuric acid, reagents are over one year old and/or prohibited OTO kits and/or test strips are being used.	C