

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
BEST WESTERN MERRY MANOR INN (POOL)	REGULAR	2019-07-16	No		No Violations	
BEST WESTERN MERRY MANOR INN (POOL)	REGULAR	2022-03-08	No	4.A	Inadequate barrier.	C
				5.B.2	Flow meter not installed and/or is not accurate.	N
				3.A.5	Chemical storage areas not locked at all times.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				3.C.1	Free chlorine levels not correct and/or stabilized chlorine used in indoor pool.	C
				6.B.1	Rope and float line not present and/or not properly placed.	C
BEST WESTERN MERRY MANOR INN (POOL)	REGULAR	2022-03-10	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.F	Exposed piping not color coded or color coded correctly.	N