

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
CAMDEN RIVERHOUSE HOTEL (POOL)	REGULAR	2020-02-05	No	6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C
				6.D.3	Ring buoy with throwing rope attached not provided, ring buoy is not US Coast Guard-approved with an outside diameter of 15 inches or greater, throwing rope for the ring buoy not of a minimum 1/4 inch diameter and/or throwing rope of ring buoy is not long enough (1.5 x width of pool) or 50 feet, whichever is less.	C
CAMDEN RIVERHOUSE HOTEL (POOL)	REGULAR	2020-02-14	No	3.G.2	Appropriate test kit, DPD or FAS-DPD not provided, test kit not capable of testing for free and combined chlorine, pH, total alkalinity, calcium hardness and when used, cyanuric acid, reagents are over one year old and/or prohibited OTO kits and/or test strips are being used.	C
				6.B.1	Rope and float line not present and/or not properly placed.	C
				6.C.7	Depth markers do not meet the 4 inch minimum height, are not a contrasting color to the background on which they are applied and/or not of a permanent nature.	C