

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
COBBOSSEE MOTEL (POOL)	REGULAR	2019-07-29	Yes	4.C.1	Pedestrian access gate not self-closing, self-latching, opening outward, or can not accommodate a lock.	C
				5.B.2	Flow meter not installed and/or is not accurate.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				3.G.2	Appropriate test kit, DPD or FAS-DPD not provided, test kit not capable of testing for free and combined chlorine, pH, total alkalinity, calcium hardness and when used, cyanuric acid, reagents are over one year old and/or prohibited OTO kits and/or test strips are being used.	C
				6.C.7	Depth markers do not meet the 4 inch minimum height, are not a contrasting color to the background on which they are applied and/or not of a permanent nature.	C
				6.D.5	First aid kit, including barrier protection (gloves and rescue breathing), not available at all times.	C
				6.E.2	When required, SVRS or other approved system not installed.	C
COBBOSSEE MOTEL (POOL)	FOLLOW_UP_FULL	2019-08-22	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the tread and 2 inches on the riser.	C
				6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C