

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
PORT INN (POOL)	REGULAR	2019-05-20	No	6.C.3	Depth markers on deck are not within 18 inches of the water edge and/or are not positioned to be read while standing on the deck facing the water.	C
				5.D.3	A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.	N
				6.D.4	Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit.	C
PORT INN (POOL)	REGULAR	2022-09-27	Yes	3.A.2	Public pool or spa establishment owner not retaining a pool or spa supervisor with CPO training and certification or equivalent.	C
				5.B.3	Disinfectant feeder not installed, not functioning properly, prohibited feeding of a supplemental sanitizer through skimmer basket is allowed, supplemental sanitizer added directly into the pool when in use, supplemental feeding of sanitizer not done in accordance with manufacturers directions, forbidden undissolved sanitizers found in skimmer basket while pool or spa in use, and/or prohibited stabilized chlorine used for indoor pools.	N
				5.B.2	Flow meter not installed and/or is not accurate.	N
				3.A.5	Chemical storage areas not locked at all times.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C
				6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C
				6.B.1	Rope and float line not present and/or not properly placed.	C
				5.D.3	A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.	N

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
				6.D.4	Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit.	C
PORT INN (POOL)	REGULAR	2023-06-09	No		No Violations	