

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
FLAGSHIP INN (POOL)	REGULAR	2018-09-05	No		No Violations	
FLAGSHIP INN (POOL)	REGULAR	2023-09-21	Yes	4.C.1	Pedestrian access gate not self-closing, self-latching, opening outward, or can not accommodate a lock.	C
				4.C.1.a	Gate latch not at correct height.	C
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				6.G.2	Procedures and instructions for system operations of valves not referenced by their respective numbers.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				3.G.4	Material Safety Data Sheets not available for inspection.	N
				3.A.4	Manufacturers instructions not available.	C
				6.D.4	Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit.	C
FLAGSHIP INN (POOL)	NEWOWNER	2024-03-06	No	4.A	Inadequate barrier.	C