

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
FOUR POINTS SHERATON (POOL)	REGULAR	2019-09-25	No	6.F	Exposed piping not color coded or color coded correctly.	N
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the tread and 2 inches on the riser.	C
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
BANGOR AVIATOR (POOL)	REGULAR	2023-07-21	No	6.F	Exposed piping not color coded or color coded correctly.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C