

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
GREENLAND COVE CAMPGROUND (POOL)	REGULAR	2019-06-12	Yes	8.A.2	All portions of the water distribution system serving the public pool or spa not protected against backflow and back-siphonage and/or water introduced into the public pool or spa is not supplied through an air gap or by another approved method.	C
				5.B.2	Flow meter not installed and/or is not accurate.	N
				3.C.1	Free chlorine levels not correct and/or stabilized chlorine used in indoor pool.	C
				6.C.9	The transition point of a new pool from the shallow area to the deep area not visually set apart with a 4-inch marked line of contrasting color.	C
				6.E.2	When required, SVRS or other approved system not installed.	C
GREENLAND COVE CAMPGROUND (POOL)	FOLLOW_UP_ FULL	2019-06-18	No	6.C.9	The transition point of a new pool from the shallow area to the deep area not visually set apart with a 4-inch marked line of contrasting color.	C
GREENLAND COVE CAMPGROUND (POOL)	REGULAR	2022-05-24	No	3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C
				6.C.9	The transition point of a new pool from the shallow area to the deep area not visually set apart with a 4-inch marked line of contrasting color.	C