

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
HARRASEEKET INN (POOL)	REGULAR	2020-11-12	No		No Violations	
HARRASEEKET INN (POOL)	REGULAR	2023-05-10	No	3.A.2	Public pool or spa establishment owner not retaining a pool or spa supervisor with CPO training and certification or equivalent.	C
HARRASEEKET INN (POOL)	NEWOWNER	2023-06-05	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				3.A.4	Manufacturers instructions not available.	C