

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
LAZY FROG CAMPGROUND (POOL)	REGULAR	2022-08-02	No	8.A.2	All portions of the water distribution system serving the public pool or spa not protected against backflow and back-siphonage and/or water introduced into the public pool or spa is not supplied through an air gap or by another approved method.	C
				5.B.3	Disinfectant feeder not installed, not functioning properly, prohibited feeding of a supplemental sanitizer through skimmer basket is allowed, supplemental sanitizer added directly into the pool when in use, supplemental feeding of sanitizer not done in accordance with manufacturers directions, forbidden undissolved sanitizers found in skimmer basket while pool or spa in use, and/or prohibited stabilized chlorine used for indoor pools.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				3.G.4	Material Safety Data Sheets not available for inspection.	N
				3.A.4	Manufacturers instructions not available.	C
				5.D.3	A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.	N