

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation   | Severity |
|--------------------|------------|------------|-------|------------|--|----------|
| HID'N PINES (POOL) | REGULAR    | 2021-09-07 | No    | 3.G.1      | Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available. | C        |
|                    |            |            |       | 6.D.3      | Ring buoy with throwing rope attached not provided, ring buoy is not US Coast Guard-approved with an outside diameter of 15 inches or greater, throwing rope for the ring buoy not of a minimum 1/4 inch diameter and/or throwing rope of ring buoy is not long enough (1.5 x width of pool) or 50 feet, whichever is less.  | C        |
| HID'N PINES (POOL) | REGULAR    | 2021-09-07 | No    | 3.G.1      | Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available. | C        |