

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
HOLIDAY INN BY THE BAY (POOL)	REGULAR	2019-08-07	No	5.B.4.a.i	Circulation system does not meet turnover rate requirements for swimming pools - once every 6 hours.	N
HOLIDAY INN BY THE BAY (POOL)	REGULAR	2022-06-16	Yes	3.G.2	Appropriate test kit, DPD or FAS-DPD not provided, test kit not capable of testing for free and combined chlorine, pH, total alkalinity, calcium hardness and when used, cyanuric acid, reagents are over one year old and/or prohibited OTO kits and/or test strips are being used.	C
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				3.C.1	Free chlorine levels not correct and/or stabilized chlorine used in indoor pool.	C
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the tread and 2 inches on the riser.	C
				6.E.2	When required, SVRS or other approved system not installed.	C