

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
HOMEWOOD SUITES (POOL)	REGULAR	2020-02-27	No	3.C.1	Free chlorine levels not correct and/or stabilized chlorine used in indoor pool.	C
				6.E.1	When required, suction grates are not installed and/or approved.	C
HOMEWOOD SUITES (POOL)	REGULAR	2024-01-22	No	6.E.1	When required, suction grates are not installed and/or approved.	C