Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
INN BY THE SEA (POOL)	REGULAR	2019-09-04	No	4.C.1	Pedestrian access gate not self- closing, self-latching, opening outward, or can not accommodate a lock.	С
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	С
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.D.3	Ring buoy with throwing rope attached not provided, ring buoy is not US Coast Guard-approved with an outside diamenter of 15 inches or greater, throwing rope for the ring buoy not of a minimum 1/4 inch diamenter and/or throwing rope of ring buoy is not long enough (1.5 x width of pool) or 50 feet, whichever is less.	С
INN BY THE SEA (POOL)	REGULAR	2023-10-10	No	4.C.1	Pedestrian access gate not self- closing, self-latching, opening outward, or can not accommodate a lock.	С