

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
KATAHDIN SHADOWS CAMPGROUND INC (POOL)	REGULAR	2018-08-01	Yes	3.A.2	Public pool or spa establishment owner not retaining a pool or spa supervisor with CPO training and certification or equivalent.	C
				5.B.2	Flow meter not installed and/or is not accurate.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				3.A.4	Manufacturers instructions not available.	C
				3.C.1	Free chlorine levels not correct and/or stabilized chlorine used in indoor pool.	C
				6.D.5	First aid kit, including barrier protection (gloves and rescue breathing), not available at all times.	C
				6.D.1	Lifesaving equipment not conspicuously and conveniently on hand at all times by the side of the pool.	C
				5.D.3	A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.	N
				6.D.4	Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit.	C
KATAHDIN SHADOWS CAMPGROUND INC (POOL)	REGULAR	2021-05-27	No	3.A.2	Public pool or spa establishment owner not retaining a pool or spa supervisor with CPO training and certification or equivalent.	C
				5.B.2	Flow meter not installed and/or is not accurate.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				6.E.2	When required, SVRS or other approved system not installed.	C
				6.D.4	Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit.	C