

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation | Severity |
|---------------------------|------------|------------|-------|------------|---|----------|
| LINEKIN BAY RESORT (POOL) | REGULAR | 2019-06-06 | No | 5.B.2 | Flow meter not installed and/or is not accurate. | N |
| | | | | 3.A.5 | Chemical storage areas not locked at all times. | N |
| | | | | 6.F | Exposed piping not color coded or color coded correctly. | N |
| | | | | 5.D.3 | A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted. | N |
| LINEKIN BAY RESORT (POOL) | REGULAR | 2023-09-14 | No | 5.B.1 | Pool data sheet not posted and/or does not contain required information. | N |
| | | | | 3.A.3 | Routine operating procedures not posted and/or available for viewing by the Department. | C |
| | | | | 6.G.1 | Valves not tagged with metal or rigid plastic tags. | N |
| | | | | 6.C.1 | Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool. | C |
| | | | | 5.D.3 | A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted. | N |
| | | | | 6.D.4 | Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit. | C |