

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
LINEKIN BAY RESORT (POOL)	REGULAR	2019-06-06	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				3.A.5	Chemical storage areas not locked at all times.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				5.D.3	A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.	N
LINEKIN BAY RESORT (POOL)	REGULAR	2023-09-14	No	5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C
				5.D.3	A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.	N
				6.D.4	Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit.	C