

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
LIMESTONE COMMUNITY SCHOOL POOL	REGULAR	2019-10-16	No	5.B.4.a.i	Circulation system does not meet turnover rate requirements for swimming pools - once every 6 hours.	N
				5.B.3	Disinfectant feeder not installed, not functioning properly, prohibited feeding of a supplemental sanitizer through skimmer basket is allowed, supplemental sanitizer added directly into the pool when in use, supplemental feeding of sanitizer not done in accordance with manufacturers directions, forbidden undissolved sanitizers found in skimmer basket while pool or spa in use, and/or prohibited stabilized chlorine used for indoor pools.	N
				5.B.2	Flow meter not installed and/or is not accurate.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				3.C.1	Free chlorine levels not correct and/or stabilized chlorine used in indoor pool.	C
				5.D.2	Goggles and other miscellaneous items furnished by management are not being sanitized after each usage.	N
LIMESTONE COMMUNITY SCHOOL	FOLLOW_UP_FULL	2019-11-21	No	5.B.1	Pool data sheet not posted and/or does not contain required information.	N