

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
CAMDEN HILLS RV RESORT	REGULAR	2019-09-19	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
CAMDEN HILLS RV RESORT	REGULAR	2022-07-14	No	3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C
CAMDEN HILLS RV RESORT	REGULAR	2022-07-14	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	