

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
GREATER PORTLAND YMCA POOL	REGULAR	2018-08-29	No	5.B.1	Pool data sheet not posted and/or does not contain required information.	N
GREATER PORTLAND YMCA POOL	REGULAR	2018-08-29	No		No Violations	
GREATER PORTLAND YMCA POOL	REGULAR	2022-07-20	No	3.C.1	Free chlorine levels not correct and/or stabilized chlorine used in indoor pool.	C
				6.D.2	Not equipped with a light, strong pole not less than 12 feet long, including a body hook.	C