

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
WESTBROOK COMMUNITY CTR POOL	REGULAR	2018-12-12	No	3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
WESTBROOK COMMUNITY CTR POOL	REGULAR	2022-04-21	No		No Violations	
WESTBROOK COMMUNITY CTR POOL	REGULAR	2024-03-19	No	5.C	Pool and/or spa facilities not maintained in a safe and sanitary manner.	N
				5.A.3	Dressing and sanitary facilities not properly maintained in a sanitary condition, not well drained, not properly constructed of impervious materials, not maintained, do not have separations for each sex, not well lit and/or not properly ventilated.	N