

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
NAPLES KOA (POOL)	REGULAR	2019-08-16	No	3.C.3	pH not correct.	C
NAPLES KOA HOLIDAY (POOL)	NEWOWNER	2022-08-04	No	4.C.1	Pedestrian access gate not self-closing, self-latching, opening outward, or can not accommodate a lock.	C
				3.A.5	Chemical storage areas not locked at all times.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				3.C.3	pH not correct.	C
NAPLES KOA (POOL)	REGULAR	2023-08-04	No		No Violations	