

| Establishment Name                   | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation   | Severity |
|--------------------------------------|------------|------------|-------|------------|--|----------|
| NE'RE BEACH FAMILY CAMPGROUND (POOL) | REGULAR    | 2021-07-21 | No    | 3.G.1      | Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available. | C        |
|                                      |            |            |       | 6.C.8      | The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.   | C        |
|                                      |            |            |       | 6.C.1      | Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.   | C        |