

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
PINEDEROSA CAMPING AREA (POOL)	REGULAR	2019-07-31	No	6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the tread and 2 inches on the riser.	C
				6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C
PINEDEROSA CAMPING AREA (POOL)	REGULAR	2022-09-01	No	3.A.5	Chemical storage areas not locked at all times.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				3.G.4	Material Safety Data Sheets not available for inspection.	N
				3.G.2	Appropriate test kit, DPD or FAS-DPD not provided, test kit not capable of testing for free and combined chlorine, pH, total alkalinity, calcium hardness and when used, cyanuric acid, reagents are over one year old and/or prohibited OTO kits and/or test strips are being used.	C
				6.D.4	Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit.	C