

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
PRESQUE ISLE INN & CONV CENTER (POOL)	FOLLOW_UP_FULL	2019-11-04	No	6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the tread and 2 inches on the riser.	C
				6.C.9	The transition point of a new pool from the shallow area to the deep area not visually set apart with a 4-inch marked line of contrasting color.	C
PRESQUE ISLE INN & CONV CENTER (POOL)	NEWOWNER	2021-11-30	No	5.B.4.a.i	Circulation system does not meet turnover rate requirements for swimming pools - once every 6 hours.	N
				5.B.2	Flow meter not installed and/or is not accurate.	N
				3.G.4	Material Safety Data Sheets not available for inspection.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C