

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
FORT FAIRFIELD PUBLIC POOL	REGULAR	2018-08-08	No	4.C.1	Pedestrian access gate not self-closing, self-latching, opening outward, or can not accommodate a lock.	C
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				6.D.1	Lifesaving equipment not conspicuously and conveniently on hand at all times by the side of the pool.	C
				6.D.4	Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit.	C