

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
RIVERSIDE PARK CAMPGROUND (POOL)	REGULAR	2019-07-11	No	6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C
RIVERSIDE PARK CAMPGROUND (POOL)	REGULAR	2023-06-01	Yes	4.C.1	Pedestrian access gate not self-closing, self-latching, opening outward, or can not accommodate a lock.	C
				4.C.1.a	Gate latch not at correct height.	C
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				3.G.4	Material Safety Data Sheets not available for inspection.	N
				3.A.4	Manufacturers instructions not available.	C
				6.D.4	Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit.	C
RIVERSIDE PARK CAMPGROUND (POOL)	REGULAR	2023-06-06	Yes	4.C.1	Pedestrian access gate not self-closing, self-latching, opening outward, or can not accommodate a lock.	C
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				3.G.4	Material Safety Data Sheets not available for inspection.	N
				3.A.4	Manufacturers instructions not available.	C
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C
				6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C
				6.B.1	Rope and float line not present and/or not properly placed.	C
RIVERSIDE PARK CAMPGROUND (POOL)	NEWOWNER	2023-08-04	No	6.G.1	Valves not tagged with metal or rigid plastic tags.	N

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C