

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation | Severity |
|-----------------------|------------|------------|-------|------------|--|----------|
| SEA TURN MOTEL (POOL) | REGULAR | 2023-07-10 | No | 4.C.1 | Pedestrian access gate not self-closing, self-latching, opening outward, or can not accommodate a lock. | C |
| | | | | 3.G.1 | Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available. | C |
| | | | | 6.C.8 | The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the tread and 2 inches on the riser. | C |