

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
SHIRETOWN INN & SUITES (POOL)	REGULAR	2019-06-18	No	6.F	Exposed piping not color coded or color coded correctly.	N
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C
				6.E.2	When required, SVRS or other approved system not installed.	C
				5.D.3	A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.	N