

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
THE SPARHAWK OCEANFRONT RESORT (POOL)	REGULAR	2023-03-29	No	4.C.1	Pedestrian access gate not self-closing, self-latching, opening outward, or can not accommodate a lock.	C
				6.F	Exposed piping not color coded or color coded correctly.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N