

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
STAGE NECK INN (POOL)	REGULAR	2022-12-19	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C