

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
NELLIE LITTLEFIELD HOUSE INN AND SPA (POOL)	REGULAR	2019-06-25	No	5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.F	Exposed piping not color coded or color coded correctly.	N