

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation | Severity |
|---------------------------------------|------------|------------|-------|------------|--|----------|
| UNIVERSITY INN ACADEMIC SUITES (POOL) | REGULAR | 2019-06-27 | No | 5.B.2 | Flow meter not installed and/or is not accurate. | N |
| | | | | 5.B.1 | Pool data sheet not posted and/or does not contain required information. | N |
| | | | | 6.B.1 | Rope and float line not present and/or not properly placed. | C |
| | | | | 6.D.5 | First aid kit, including barrier protection (gloves and rescue breathing), not available at all times. | C |