

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
UNIVERSITY OF MAINE AT PI POOL	REGULAR	2019-06-19	No	5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				6.G.2	Procedures and instructions for system operations of valves not referenced by their respective numbers.	N
				6.F	Exposed piping not color coded or color coded correctly.	N