

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
VILLAGER MOTEL (POOL)	REGULAR	2020-06-29	No		No Violations	
VILLAGER MOTEL (POOL)	REGULAR	2023-07-18	No	6.F	Exposed piping not color coded or color coded correctly.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.D.4	Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit.	C