

| Establishment Name    | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation  | Severity |
|-----------------------|------------|------------|-------|------------|---|----------|
| VILLAGER MOTEL (POOL) | REGULAR    | 2020-06-29 | No    |            | No Violations   |          |
| VILLAGER MOTEL (POOL) | REGULAR    | 2023-07-18 | No    | 6.F        | Exposed piping not color coded or color coded correctly.  | N        |
|                       |            |            |       | 6.G.1      | Valves not tagged with metal or rigid plastic tags.   | N        |
|                       |            |            |       | 6.D.4      | Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit. | C        |